GREASE INTERCEPTOR GREASE INTERCEPTOR PREVENTS GREASE FROM ENTERING COMMUNITY 1500 GALLON CAPACITY SEWAGE COLLECTION SYSTEM & CAUSING IT IS THE EXCAVATOR'S OR FREQUENT LINE PLUGGING **INSTALLER'S RESPONSIBILITY** FOR NON-TRAFFIC APPLICATIONS TO REQUEST OUR LARGE ACCESS OPENINGS PROVIDE INSTALLATION GUIDELINES STANDARD FOR COLORADO & WYOMING **EASIER PUMPING & MAINTENANCE** PRIOR TO INSTALLING THIS **TANK** 2 COMPARTMENT TANK WITH APPROXIMATELY 60% OF - 126" TANK O.D. -CAPACITY ON INLET SIDE WITHSTANDS UP TO 6' OF BURY. RISERS ARE AVAILABLE FOR **INLET & OUTLET** OPTIONS: - 24" I.D. MANHOLE RISERS - ROOF OF TOP SECTION FOR TRAFFIC LOADINGS 68" TANK - GAS TIGHT CAST IRON RINGS & COVERS O.D. PIPING KNOCKOUTS 16" FROM END OF TANK TO CENTER OF KNOCKOUT TO 1500 ALLOW FOR CONCRETE TO BE BROKEN OUT TO ALLOW FOR SIDE INLET OR VAUGHN **OUTLET PIPE AT SAME HEIGHT AS** STANDARD INLET & OUTLET, TYP. OF 4 4" THICK WALLS & FLOOR, 5" THICK ROOF DURING PRODUCTION, "TANK SIZE" & *NOTE: WALLS & DIVIDER DO TAPER, "VAUGHN" ARE STAMPED IN LID. "IN" & THICKNESSES DO DECREASE TO ALLOW FOR "OUT" ARE MARKED ON TANK ENDS **PLAN VIEW** FORM REMOVAL; THE AVG. WALL & DIVIDER THICKNESSES ARE LISTED **APPROVED BY: OUR STANDARD 24" DIAMETER CAST** IRON RINGS & COVERS, TYP. OF 2 DATE: 24" I.D. MANHOLE RISER AS REQUIRED. 9"W X 16"L TYP. INLET/OUTLET END; AVAILABLE IN **REMOVABLE** POLYLOK PIPE SEAL IS CAST IN ON 2".3".4".6".8" OR 12" HEIGHTS INSPECTION LID THE OUTLET END FOR OPTIONAL -**OVER DIVIDER** CONSEAL JOINT SEALANT, OR VENT, 20" OVER & 5" ABOVE OUTLET CONTRACTOR TO GROUT PIPING BLOCKOUTS WITH POLYLOK PIPE SEALS CAST IN TANK FOR INLET & OUTLET PIPING (TYPICAL) 6" 24" DIA. ACCESS 15" CONTRACTOR'S 4" PIPES OPENING, TYP. OF 2 3" **CONTRACTOR SUPPLIED** FREE AIR SPACE IN 4" SDR35 INLET & OUTLET TEES **DIVIDER ABOVE** 58" CROSSOVER -44" 68" CONSEAL JOINT SEALANT 55" 4" PVC CROSSOVER PIPE TANK WEIGHTS: INSTALLED PRIOR TO DELIVERY - COMPLETE INTERCEPTOR: 14,000 LBS. DIGGING SPECIFICATIONS: - 58" BELOW THE INLET - EXCAVATION TO BE 61/2' WIDE X 14' LONG - SEE OUR INSTALLATION GUIDELINES PRIOR TO INSTALLING THIS TANK 10'-6" CONCRETE: 4,000 P.S.I. (MINIMUM) REINFORCING: REBAR & WELDED WIRE FABRIC SECTION VIEW ACTUAL DIMENSIONS OF CONCRETE PRODUCTS MAY VARY SLIGHTLY aughn oncrete products, inc. DRAWING IS NOT TO SCALE 1500 GAL GI, NON-TRAFFIC.DWG DATE CREATED: 11/04 UPDATED: 8/2021

PRECAST CONCRETE

12650 Tucson Street • Henderson, Colorado 80640 • 303-659-3747, Fax 303-659-1333 2671 South Greeley Hwy • Cheyenne, Wyoming 82007 • 307-634-0695, Fax 307-634-0694